



# CERTIFICATE

SC0622-15

## Shut-off valve Böhmer BBF/KSF for district heating/cooling systems

### Holder/Issued to/

Komptek AB, Armaturvägen 3D, SE-136 50 Jordbro, Sweden

### Manufacturer

Böhmer GmbH, Gedulderweg 95, DE-445 37 Sprockhövel, Germany

### Product name

Böhmer BBF/KSF

### Product description

Ball valves in sizes DN 150 - DN 800.

### Certification

The product described here fulfils the requirements in SP's *Certification rules for P-marking of shut-off valves in district heating and district cooling systems, SPCR 145*, and also the requirements set out in the Swedish District Heating Association's document *Certification of valves, test and inspection requirement, no. D:210 (December 2009)*.

### Associated documents

- Product description – *BBF/KSF*
- *Böhmer Kugelhähne Ball Valves, Komptek AB – Driftinstruktioner* dated 11/2008

### Marking

Each product that complies with the certified product may display a quality symbol, as shown below to the right.

### Test report

SP report 5P01982-B dated 2015-05-25

### Validity

This certificate is valid until not longer than 30<sup>th</sup> July 2020.

### Miscellaneous


SP exercises surveillance inspection in accordance with Items 4 and 5 in SPCR 145.

The certificate was originally issued 30<sup>th</sup> July 2015.

### SP Technical Research Institute of Sweden Certification

Johan Åkesson  
Product Certification Manager

Emma Ekberg  
Certification Officer



Certificate No. SC0622-15 issue 1, 2015-07-30

### SP Technical Research Institute of Sweden

Box 857, SE-501 15 Borås, Sweden  
Phone: +46 10-516 50 00  
E-mail: info@sp.se  
www.sp.se

This certificate may not be reproduced other than in full,  
except with the prior written approval by SP.

SPs Certification rule SPCR 145

5P01982-02